



# Asbestos Bulk Analysis Report

7469 Whitepine Rd  
 North Chesterfield, VA 23237  
 Telephone: 800.347.4010

**Report Number:** 24-08-04905

**Client:** National Econ Corp.  
 4515 Poplar Ave., Ste. 425  
 Memphis, TN 38117

**Received Date:** 08/28/2024  
**Analyzed Date:** 08/28/2024  
**Reported Date:** 08/28/2024

**Project/Test Address:** MSCS; Norris Elementary; 1690 Norris Rd

**Client Number:**  
 44-2606

## Laboratory Results

**Fax Number:**  
 901-767-2466

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-08-04905-001	1	--	Pale Beige to Off-White Brittle; Homogeneous	NAD	1% Cellulose 1% Wollastonite 1% Talc 97% Non-Fibrous
24-08-04905-002	2	--	Pale Beige to Pale Gray Brittle; Homogeneous	NAD	1% Talc 99% Non-Fibrous
24-08-04905-003	3	--	Pale Beige to Pale Gray Brittle; Homogeneous	2% Chrysotile	98% Non-Fibrous
				<b>Total Asbestos: 2%</b>	
24-08-04905-004	4	--		Did Not Analyze (Positive Stop)	
24-08-04905-005	5	--		Did Not Analyze (Positive Stop)	

# Environmental Hazards Services, L.L.C

**Client Number:** 44-2606

**Report Number:** 24-08-04905

**Project/Test Address:** MSCS; Norris Elementary; 1690 Norris Rd

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-08-04905-006	6	--		Did Not Analyze (Positive Stop)	
24-08-04905-007	7	--		Did Not Analyze (Positive Stop)	
24-08-04905-008	8	--		Did Not Analyze (Positive Stop)	
24-08-04905-009	9	--		Did Not Analyze (Positive Stop)	
24-08-04905-010	10	--	Gray Pliable; Homogeneous	NAD	15% Cellulose 85% Non-Fibrous
24-08-04905-011	11	--	Gray Pliable; Homogeneous	NAD	15% Cellulose 85% Non-Fibrous
24-08-04905-012	12	--	Gray Pliable; Homogeneous	NAD	15% Cellulose 85% Non-Fibrous
24-08-04905-013	13	--	Gray Pliable; Homogeneous	NAD	15% Cellulose 85% Non-Fibrous
24-08-04905-014	14	--	Gray Pliable; Homogeneous	NAD	15% Cellulose 85% Non-Fibrous

# Environmental Hazards Services, L.L.C

**Client Number:** 44-2606

**Report Number:** 24-08-04905

**Project/Test Address:** MSCS; Norris Elementary; 1690 Norris Rd

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-08-04905-015	15	--	Silver Pliable; Homogeneous	NAD	100% Non-Fibrous
24-08-04905-016	16	--	Silver Pliable; Homogeneous	NAD	100% Non-Fibrous
24-08-04905-017	17	--	Silver Pliable; Homogeneous	NAD	100% Non-Fibrous
24-08-04905-018	18	--	Silver Pliable; Homogeneous	NAD	100% Non-Fibrous
24-08-04905-019	19	--	Pale Gray Brittle; Homogeneous	3% Chrysotile	3% Cellulose 94% Non-Fibrous
<b>Total Asbestos: 3%</b>					
24-08-04905-020	20	--		Did Not Analyze (Positive Stop)	
24-08-04905-021	21	--		Did Not Analyze (Positive Stop)	
24-08-04905-022	22	--		Did Not Analyze (Positive Stop)	
24-08-04905-023	23	--	Silver Pliable; Homogeneous	NAD	100% Non-Fibrous

# Environmental Hazards Services, L.L.C

Client Number: 44-2606

Report Number: 24-08-04905

Project/Test Address: MSCS; Norris Elementary; 1690 Norris Rd

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
24-08-04905-024	24	--	Pale Tan-Gray Brittle; Homogeneous	2% Chrysotile	98% Non-Fibrous
<b>Total Asbestos: 2%</b>					
24-08-04905-025	25	--		Did Not Analyze (Positive Stop)	
24-08-04905-026	26	--		Did Not Analyze (Positive Stop)	
24-08-04905-027	27	--		Did Not Analyze (Positive Stop)	
24-08-04905-028	28	--		Did Not Analyze (Positive Stop)	

# Environmental Hazards Services, L.L.C

**Client Number:** 44-2606

**Report Number:** 24-08-04905

**Project/Test Address:** MSCS; Norris Elementary; 1690 Norris Rd

---

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
-------------------	----------------------	------------	-----------------------	----------	-----------------

---

**QC Sample:** 91-M22022-4


**QC Blank:** SRM 1866 Fiberglass

**Reporting Limit:** 1% Asbestos

**Method:** EPA Method 600/R-93/116, EPA Method 600/M4-82-020

**Analyst:** Mark Case

Reviewed By Authorized Signatory:



Melissa Kanode  
QA/QC Clerk

These results are based on a comparative visual estimate. The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Each distinct component in an inhomogeneous sample was analyzed separately and reported as a composite. Results represent the analysis of samples submitted by the client. Sample location, description, area, volume, etc., was provided by the client. This report cannot be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. All information concerning sampling location, date, and time can be found on Chain-of-Custody. Environmental Hazards Services, L.L.C. does not perform any sample collection. . NVLAP #101882-0 VELAP 460172

Environmental Hazards Services, L.L.C. recommends reanalysis by point count (for more accurate quantification) or Transmission Electron Microscopy (TEM), (for enhanced detection capabilities) for materials regulated by EPA NESHAP (National Emission Standards for Hazardous Air Pollutants) and found to contain less than ten percent (<10%) asbestos by polarized light microscopy (PLM). Both services are available for an additional fee.

400 Point Count Analysis, where noted, performed per EPA Method 600/R-93/116 with a Reporting Limit of 0.25%.

---

LEGEND: NAD = no asbestos detected

---



# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Asbestos Chain of Custody Form

*Normiz*

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK					AIR			COMMENTS		
					PLM	Point Count 400	Point Count 1000	TEM Bulk	PCM	TEM AHERA	NIOSH 7402	Time In Total Minutes		Flow Rate In L/Min	Volume In Total Liters
16	16	A	✓												
17	17	↓	✓												
18	18	↓	✓												
19	19	B	✓												
20	20	↓	✓												
21	21	↓	✓												
22	22	↓	✓												
23	23														
24	24	C	✓												
25	25	↓	✓												
26	26	↓	✓												
27	27	↓	✓												
28	28	↓	✓												
29															
30															
31															
32															
33															
34															
35															
36															
37															
38															
39															
40															
41															
42															
43															
44															
45															

Received By: *C. [Signature]*

EHS Order #: 4905

Signature: *[Signature]*

Date: 8.24.14 Time: 9:05 AM PM