



Department of Procurement Services

160 Glenn Rogers Sr. · Room 126 · Memphis, TN 38112 · (901) 416-5376

March 28, 2025

Addendum #2: **IFB 040725BS Woodstock MS Gym Bleacher Renovations**

Dear Bidders:

This Addendum forms a part of the Contract Documents and modifies the Plans and Specifications dated March 27, 2025. The Contractor shall acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Item #1 – PART IV: SCOPE OF WORK (PAGE 14)

Please adhere to the following **additions** and/or **revisions** to the original scope of work that was included with this bid:

- **Shop drawings are required and reviewed with the owner's representative prior to actual work starting.**
- **Correction to Addendum 1 - The new bleacher system shall extend wall to wall; however, the new bleacher shall allow a **4' egress** path between walls and end of new bleacher system for egress and maintenance. Install removable side aprons on each side on new bleacher system.**

Thank you,
Procurement Services