



Department of Facilities and Maintenance
1364 Farmville Road. Memphis, Tennessee 38122 • (901) 416-0049

General Services Department

Attachment 'B'

DATE: August 15, 2022

To: Emily Carter, Project Manager

From. James Benton, Asbestos Supervisor

Subject: White Sta.High boiler replacement Project

The following areas have been identified with Asbestos-containing materials as defined by OSHA and EPA.

Building #1,

1. Boiler insulation
2. Cement elbows and tees.pipes

Please contact me via email BentonJR@scsk12.org and let me know if I Can be of any further assistance.