



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB #112524MT - Bolton High School Sports Field LED Exterior Lighting

1. The Scope of Work mentions 50/30 FC for the Baseball Infield and Outfield. At the site visit, it was discussed that the existing wooden poles would need to be replaced. Can you please confirm?

Yes, the wood poles must be replaced with concrete stub bases, with adequate steel poles to achieve the required foot candles.

2. Also, it was mentioned that there were additional drawings for the project. Would you be able to send those to us?

The drawing was posted Wednesday to the SCS portal under this bid information and sent to all bidders who provided a valid email at the pre-bid meeting held 11/13/2024 (11:00 AM CST).