



# National Econ Corporation

4515 Poplar Ave. # 425  
Memphis, Tennessee 38117  
Phone 901-761-5431 / Fax 901-767-2466

CONFIDENTIAL AND PRIVILEGED

*Limited Asbestos Survey*

**Shady Grove (roofing)**

**5360 Shady Grove**

**Memphis, TN**

---

**August 21, 2024**

Volume 1 of 1

**Prepared for:**

**Memphis Shelby County B.O.E Maintenance Department**

**1364 Farmville Road**

**Memphis, TN**

---

This report was prepared for **MSCS**, by independent consultants and is based, in part on information not within the control of either **MSCS**, or consultants. While it is believed that all information contained herein will be reliable under conditions and subject to the limitations set forth herein, neither **MSCS**, nor the consultants guarantee the accuracy thereof. The use of this report, or any information contained herein, shall be at the user's sole risk, regardless of any fault or negligence **MSCS**, or the consultants. Use of this report or any **MSCS**, and consultants from and against all liability (including, but not limited to, liability for special, indirect or consequential damages) whether arising in contract or due to **MSCS**, and/or consultant's negligence, strict liability or otherwise.

## Executive Summary

This report has been prepared for Memphis Shelby County Schools. Our intent is to provide documentation that will inform you of asbestos containing materials (ACM) used in the construction of Shady Grove located at 5360 Shady Grove in Memphis, Tennessee.

A limited asbestos survey was conducted at the above address. Survey protocols, as established by the Environmental Protection Agency (EPA) were strictly followed. Five (5) bulk samples were collected and transported under chain of custody protocol by Cordell Cooper, to a pre-qualified laboratory for microscopic analysis. Samples were analyzed by Polarized Light Microscopy (PLM) coupled with dispersion staining to determine the content and type of asbestos.

Primary Analysis was provided by National Econ Corporation, Memphis, Tennessee. National Econ Corporation participates in the American Industrial Hygiene Association (AIHA) - Bulk Asbestos PAT Program (BAPAT) with an accreditation number- 102259.

Suspect ACM are categorized under the Asbestos Hazardous Emergency Response Act (AHERA) as:

- 1) Surface Materials (SM), 2) Thermal System Insulation (TSI), and 3) Miscellaneous Materials (MM). Suspect asbestos containing material (ACM) at the subject location are indicated in the following:

SM

TSI

MM

Roofing Materials  
Roofing Flashing

**\*Non – Friable asbestos containing material**

**\*\* Friable asbestos containing material**

National Econ Corporation assumes no responsibility for identification of “atypical” ACM, used in the construction trade.

**Sincerely,**

National Econ Corporation

*Chester Ervin*

Chester Ervin / Manager  
General Manager

*Marvinetta Cooper*

Marvinetta Cooper  
Industrial Hygienist

No Asbestos containing material(s) were detected during an inspection of Shady Grove located at 5360 Shady Grove in Memphis, Tennessee, as supported by the laboratory reports contained herein.

## **NO ASBESTOS DETECTED**

### **LIMITATIONS**

The conclusions presented in this report are the professional opinions of National Econ Corporation. These opinions are based solely upon visual observations at the site and laboratory analysis of the tested samples. They are intended exclusively for the purpose outlined herein, and for the site location and project indicated.

This report is intended for the sole use of Memphis Shelby County Schools. The use or re-use of this document or the findings, conclusion or recommendations presented herein, by any other party or parties is at the sole risk of said user. Recognizing that even the most comprehensive survey may fail to detect ACMF at a particular site, this study was not intended to identify all potential ACMF present in the building or at the site for such reasons as (1) the possible existence of buried, covered and inaccessible areas and features; and (2) the limited number of samples collected. Samples were collected from materials of similar appearance, age, use, type, color and/or texture. However, this does not guarantee that they are of the same composition. No guarantee is expressed or implied that all ACMF has been identified. National Econ Corporation assumes no responsibility for the identification of suspect asbestos containing materials which are concealed and/or inaccessible (i.e., carpet mastic under carpet, locked rooms, etc.)

Services performed by National Econ Corporation were conducted in a manner consistent with that of the care and skill ordinarily and currently exercised by members of the same profession that even the most comprehensive Scope of Services may fail to detect environmental liabilities on a particular site. Therefore, National Econ Corporation cannot act as insurers and cannot "certify" that a site is free of environmental contamination. No expressed or implied representation or warranty is included or intended in our reports, except that our services were performed, within the limits prescribed by the Scope of Services, with the customary thoroughness and competence of our profession.

Information and opinions presented herein apply to the existing and reasonably foreseeable site conditions at the time of our investigation. They cannot necessarily apply to site changes of which this office is unaware and has not had the opportunity to review. Changes in the conditions of this property may occur with time due to natural processes or works of man on the subject property or on adjacent properties. Changes in applicable standards may also occur as a result of legislation for the broadening of knowledge. Accordingly, the findings of this report may be invalidated, wholly or in part, by changes beyond our control. National Econ Corporation trusts that the information presented herein provides the data you require. Should you have any questions or comments, please contact National Econ Corporation.

## ASBESTOS SURVEY- PLM Table

Client / Project Name: MSCS/ Shady Grove 5360 Shady Grove; Memphis, TN

Date: August 21, 2024

Sample Numbers	Material	Location	Approx. Quantity of ACM Material	Results
1	Roofing Flashing	Flashing	N/A	No Asbestos Detected
2	Roofing Materials	Northwest over Café	N/A	No Asbestos Detected
3	Roofing Materials	Loading Dock Area	N/A	No Asbestos Detected
4	Roofing Materials	West Side near hatch	N/A	No Asbestos Detected
5	Roofing Materials	Southeast Bldg.	N/A	No Asbestos Detected

National Econ Corporation  
 4515 Poplar Avenue, Suite 425 - Memphis, Tennessee 38117  
 (901) 761-5431  
**Bulk Sample Test Report**

Date Analyzed: August 21, 2024

Lab I.D. Number: 20240821

Client / Project Name: MSCS/ Shady Grove located at 5360 Shady Grove; Memphis, TN

Analyst: Netta Cooper

Sample Number	1	2	3
	Black Bituminous	Black-Yellow Bituminous	Black-Yellow Bituminous
<b>Asbestos Minerals</b>			
Chrysotile			
Anthophyllite			
Crocidolite			
Actinolite/ Tremolite			
<b>Non-Asbestos</b>			
Cellulose / Wood Fibers			
Fibrous Glass	10	5	8
Tar	50	30	38
Synthetics		3	5
Paint			
Filler / Binder	10	62	49
Granular Minerals	30		
Mastic / Glue			
Comments:	No Asbestos Detected	No Asbestos Detected	No Asbestos Detected

Analyst: *Marvinetta Cooper*

Approved Signatory: *Marvinetta Cooper*

Comments: National Econ Corporation participates in the American Industrial Hygiene Association (AIHA) - Bulk Asbestos PAT Program (BAPAT). For all obviously heterogeneous samples easily separated into sub-samples, and for layered samples, each component was analyzed separately. Disclaimer: Difficult samples such as floor tile, roofing material and samples containing < 1% asbestos, may require additional analysis by TEM or SEM if No Asbestos Detected is reported. The above test report relates only to the items tested. This test report relates only to the material analyzed. This sample was analyzed using the technique contained in 40 CFR 763, Subpart F, Appendix A (AHERA). Results from this report must not be reproduced, except in full, with the approval of National Econ Corporation.

National Econ Corporation  
 4515 Poplar Avenue, Suite 425 - Memphis, Tennessee 38117  
 (901) 761-5431  
**Bulk Sample Test Report**

Date Analyzed: August 21, 2024

Lab I.D. Number: 20240821

Client / Project Name: MSCS/ Shady Grove located at 5360 Shady Grove; Memphis, TN

Analyst: Netta Cooper

Sample Number	4	5	
	Black-Yellow Bituminous	Black-Yellow Bituminous	
<b>Asbestos Minerals</b>			
Chrysotile			
Anthophyllite			
Crocidolite			
Actinolite/ Tremolite			
<b>Non-Asbestos</b>			
Cellulose / Wood Fibers			
Fibrous Glass	6	10	
Tar	30	37	
Synthetics	6	10	
Paint			
Filler / Binder	58	43	
Granular Minerals			
Mastic / Glue			
Comments:	No Asbestos Detected	No Asbestos Detected	

Analyst: *Marvinetta Cooper*

Approved Signatory: *Marvinetta Cooper*

Comments: National Econ Corporation participates in the American Industrial Hygiene Association (AIHA) - Bulk Asbestos PAT Program (BAPAT). For all obviously heterogeneous samples easily separated into sub-samples, and for layered samples, each component was analyzed separately. Disclaimer: Difficult samples such as floor tile, roofing material and samples containing < 1% asbestos, may require additional analysis by TEM or SEM if No Asbestos Detected is reported. The above test report relates only to the items tested. This test report relates only to the material analyzed. This sample was analyzed using the technique contained in 40 CFR 763, Subpart F, Appendix A (AHERA). Results from this report must not be reproduced, except in full, with the approval of National Econ Corporation.

# Asbestos Chain-of-Custody Form

~ For Lab Use Only ~

Company Name: National Econ Corporation Account Number: \_\_\_\_\_

Address: 4515 Poplar Avenue #425 City/State/Zip: Memphis, TN 38117

Phone #: 901-761-5431 Email: Cdervinnec@earthlink.net Fax: \_\_\_\_\_

Project Name / Testing Address: MSCS/ Shady Grove 5360 Shady Grove City/State (Required): Memphis, TN

Collected by: Cordell Cooper P.O. # \_\_\_\_\_

**TURN AROUND TIMES: IF NO TAT IS SPECIFIED, SAMPLE(S) WILL BE PROCESSED AND CHARGED AS 3 - DAY TAT.**

		1 Day	2 Day	3 Day	* Same Day – Must Call Ahead				* Weekend – Must Call Ahead	
No.	Client Sample ID	HA Area #	Collection		PLM	PLM Point Count 400	PLM Point Count 1000	PLM NY Protocol	TEM - Bulk	Comments
			Date	Time						
1	1	Flashing	8/20/2024	7:30 AM						Roofing Flashing
2	2	Northwest over Cafe		AM / PM						Roofing Material
3	3	Loading Dock area		AM / PM						Roofing Material
4	4	West Side Near Hatch		AM / PM						Roofing Material
5	5	Southeast Bldg.		AM / PM						Roofing Material
6				AM / PM						
7				AM / PM						
8				AM / PM						
9				AM / PM						
10				AM / PM						
Released by: Cordell Cooper					Signature: <i>Cordell Cooper</i>				Date/Time: 8/20/2024 7:30 AM	
Received by: Marvioletta Cooper					Signature: <i>Marvioletta Cooper</i>				Date/Time: 8/20/24	





# THE STATE OF TENNESSEE

Department of Environment and Conservation  
Division of Solid Waste Management

Toxic Substances Program

124020-85718



**Cordell C Cooper**

DOB 30-Sep-1966 Sex M HGT 5' 6" WGT 215

Discipline	Accreditation	Expiration
Inspector	A-I-157425-160208	Jun-30-2025
Project Monitor	A-PM-157425-160207	Apr-30-2025



Date Issued 6/4/2024

Re-Accreditation

**Asbestos Accreditation**



## THE STATE OF TENNESSEE

Department of Environment and Conservation Division of Solid Waste Management  
Toxic Substances Program

William R. Snodgrass Tennessee Tower

312 Rosa L. Parks Avenue, 14th Floor Nashville TN 37243


By virtue of the authority vested by the Division of Solid Waste Management, the  
Company named below is hereby accredited to offer and/or conduct Asbestos activities  
pursuant to Rule 1200-01-20:

### National Econ Corporation

4515 Poplar Avenue Suite 425 Memphis TN, 38117

to conduct ASBESTOS ACTIVITIES in schools or public and commercial buildings in Tennessee.  
This firm is responsible for compliance with the applicable requirements of Rule 1200-01-20.

Discipline	Type	Accreditation Number	Effective Date	Expiration Date
Accreditation	Re-Accreditation	A-F-468-138916	September 01, 2023	September 30, 2024



Given under the Seal of the State of Tennessee in Nashville.

This 15th Day of August 2023

Division of Solid Waste Management  
Toxic Substance Program

CN-1324 (Rev 6/13)

RDA-3020