



## Department of Procurement Services

---

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

### QUESTIONS AND ANSWERS

#### **IFB 101424JKGA Districtwide Generator Preventative Maintenance Services**

1. There is no place on the pricing sheet for Annual PM  
**We are requesting cost for quarterly (vs. annual) preventative maintenance.**
2. On the pricing sheet it asks for the annual load bank test but does not state how many hours do they want the load test.  
**It would be for two (2) hours.**