



## Department of Procurement Services

---

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

### QUESTIONS AND ANSWERS

#### **IFB 09062022LB Gardenview ES & Sherwood ES Fire Alarm System Replacements**

1. The scope of work says that the old system shall be removed once the new system is complete and operational. Is there any possibility that the old system be removed or taken out of service zone by zone while the new is being installed? There would be an operational fire alarm the entire process, but it would be with the use of the old system and the new system together throughout.
  - a. No, please reference the original scope of work and the Design Guidelines.

Thank you,

Procurement Services