



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS - REV2

IFB #090324VK - Raleigh Bartlett Elementary and Geeter K-8 Roof Replacement

1. At Raleigh Bartlett Meadows, did the roofing materials test positive for asbestos?

Yes, it is the responsibility of the contractor to obtain any necessary permits associated with the removal of asbestos containing roofing materials and dispose of legally in an approved EPA landfill.

Thank you,

Procurement Services