



2010 FACILITIES ASSESSMENT OAK FOREST ELEMENTARY




| Project Data | |
|----------------------------------|------------------------|
| Location Code: | 047 |
| Address: | 7447 Nonconnah View Cv |
| Year Built: | 1994 |
| Grade Configuration: | K-5 |
| Student Capacity: | 840/920 |
| Ideal Capacity: | 650 |
| ADA Student Enrollment: | 2 |
| Size: | 11.25 acres |
| Portables: | 3,500 sf. |
| Building & Additions: | 88,000 sf. |


2010 FACILITIES ASSESSMENT OAK FOREST ELEMENTARY

| | |
|--|--|
| <p>Description:</p> <p>Self contained unit ventilators have chronic maintenance issues.</p> |  |
| <p>Timeline:</p> <p>TBD</p> | <p>Cost:</p> <p>\$1,500,000</p> |

| | |
|---|---|
| <p>Playground/Surfaces Equipment Status:</p> <p>Fully equipped, w/ various structures Has surface (Woodchips/ enclosed w/ crossties)</p> |  |
| <p>Playground Equipment / Surface Condition:</p> <p>New & used, good Poor, surface No fence enclosure</p> | |

| | |
|--|--|
| <p>Description:</p> <p>PVC Single ply roof: 7 years-fair</p> <p>Metal roof: 30 years-fair</p> |  |
| <p>Timeline:</p> <p>TBD</p> | <p>Cost:</p> <p>\$510,000</p> |

2010 FACILITIES ASSESSMENT OAK FOREST ELEMENTARY

| | |
|---|--|
| <p>Description:</p> <p>Intercom System:</p> <p>MCP35A</p> <p>Installation Date: 1993</p> |  |
| <p>Timeline:</p> <p>TBD</p> | <p>Costs:</p> <p>\$50,000</p> |