

Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB #06142024VK - Germantown HS Gym Floor Replacement

- 1. How many coats of finish and seal were you wanting on the floor, and is it oil or water based? The Contractor shall apply (2) coats of MFMA approved oil-based seal and (2) coats of MFMA oil-based finish.
- 2. What game lines are you wanting included in the price? I saw that some were in tape and some in paint. Just basketball and volleyball games lines are wanted. Also, the Contractor will <u>not</u> be expected to apply the additional (2) 2" game lines in front of the bleachers as mentioned in the scope of work in the IFB, page 14, #5 of the IFB bid document.
- 3. Also, would Shelby County Board of Education accept 1 & ½" face width board as an alternate? No, 2-1/4" width maple boards are desired.

Thank you,

Procurement Services